

Compliance Document

No. D 073342 0370 Rev. 00

Holder of Certificate: **Sungrow Power Supply Co., Ltd.**

No. 1699 Xiyou Road, New & High
Technology Industrial Development Zone,
230088 Hefei, Anhui
PEOPLE'S REPUBLIC OF CHINA

Product: **Converter**
(GRID-CONNECTED PV INVERTER)

Model(s): **SG110CX-P2-CN**

Parameters:


DC-Input	
Max Input Voltage:	1100 Vd.c.
Min MPP Voltage:	180 Vd.c.
Max MPP Voltage:	1000 Vd.c.
Max Input Current:	9*30 Ad.c.
Isc PV:	9*40 Ad.c.
AC-Output	
Rated Output Voltage:	3/N/PE 230/400 Va.c.
Rated Output Frequency:	50 Hz
Max Output Current:	183.3 Aa.c.
Rated output power:	110 kW
Max Apparent power:	121 kVA
Power Factor Range:	0.8 Leading-0.8 Lagging

Tested IEC 61727:2004
according to: IEC 62116:2014

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290223100701

Date, 2022-09-16


(Billy Qiu)